


BALLABS CERTIFIED TEST REPORT NO.: 20331.0 DATE 04/13/18  
PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO  
DESCRIPTION: GEN7 V18 LED 4"TALL HEATSINK 4"SQ CAST HOUSING DOWNLIGHT  
ACRYLIC NARROW TIR & 4"SEMI-SPEC TRIM w/FROST FILM  
ADVANCE #XI036C100V054DSM5 @ 915mA  
CATALOG NBR: 4DS-L30/835-DIM-UNV-O-N-OF-CS  
LAMP TYPE : BXRE-35E4000

## CANDLEPOWER DISTRIBUTION

VERT ANG	0	22.5	45	67.5	90	ZONAL LUMENS
0	4836.	4836.	4836.	4836.	4836.	
5	4655.	4651.	4625.	4624.	4633.	442.5
10	4153.	4146.	4131.	4129.	4136.	
15	3450.	3450.	3421.	3433.	3424.	973.8
20	2660.	2652.	2623.	2650.	2669.	
25	1943.	1932.	1896.	1932.	1940.	891.0
30	1315.	1306.	1321.	1294.	1307.	
35	784.	824.	876.	819.	773.	517.9
40	405.	437.	533.	455.	391.	
45	172.	197.	280.	204.	164.	164.4
50	44.	63.	111.	68.	40.	
55	10.	13.	30.	13.	9.	14.8
60	1.	2.	4.	2.	1.	
65	0.	0.	0.	0.	0.	.0
70	0.	0.	0.	0.	0.	
75	0.	0.	0.	0.	0.	.0
80	0.	0.	0.	0.	0.	
85	0.	0.	0.	0.	0.	.0
90	0.	0.	0.	0.	0.	



*[Handwritten signature]*



NVLAP LAB CODE 200921-0

## LUMEN SUMMARY

ZONE	LUMENS	%LAMP	%FIXT	ZONE	LUMENS	%LAMP	%FIXT
0- 30	2307.	NA.	76.8	90-120	0.	NA.	.0
0- 40	2825.	NA.	94.0	90-130	0.	NA.	.0
0- 60	3004.	NA.	100.0	90-150	0.	NA.	.0
0- 90	3004.	NA.	100.0	90-180	0.	NA.	.0
TOTAL LUMINAIRE = 0-180					3004.	NA.	100.0

IES SPACING CRITERIA: END= .7 DIAGONAL = .7 CROSS= .7

THIS BALLABS REPORT WITH THE USE OF THE NVLAP LOGO SHALL NOT BE USED BY THIS CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY NVLAP, NIST, OR ANY AGENCY OF THE FEDERAL GOVERNMENT.

BALLABS CERTIFIED TEST REPORT NO.: 20331.0 DATE 04/13/18  
 PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO  
 DESCRIPTION: GEN7 V18 LED 4" TALL HEATSINK 4" SQ CAST HOUSING DOWNLIGHT  
 ACRYLIC NARROW TIR & 4" SEMI-SPEC TRIM w/FROST FILM  
 ADVANCE #XI036C100V054DSM5 @ 915mA  
 CATALOG NBR: 4DS-L30/835-DIM-UNV-O-N-OF-CS  
 LAMP TYPE : BXRE-35E4000

\*\*\*\*\*

LUMINANCES-CD/SQ-M			
HORIZONTAL ANGLE			
VERT ANGLE	0	45	90
45	23417.	38052.	22302.
55	1718.	4983.	1547.
65	0.	0.	0.
75	0.	0.	0.
85	0.	0.	0.

\*\*MAXIMUM BRIGHTNESSES NOT MEASURED\*\*

\*\*\*\*\*

# ZONAL CAVITY COEFFICIENTS OF UTILIZATION

EFFECTIVE FLOOR CAVITY REFLECTANCE=.20

CEILING	.80				.70				.50				.30			.10			.00
WALL	.70	.50	.30	.10	.70	.50	.30	.10	.50	.30	.10	.50	.30	.10	.50	.30	.10	.00	
RCR																			
0	1.19	1.19	1.19	1.19	1.16	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00	
1	1.14	1.12	1.10	1.08	1.12	1.10	1.08	1.06	1.06	1.04	1.03	1.02	1.01	1.00	.99	.98	.97	.95	
2	1.09	1.05	1.01	.98	1.07	1.03	1.00	.97	1.00	.97	.95	.97	.95	.93	.95	.93	.91	.90	
3	1.05	.99	.95	.91	1.03	.98	.94	.90	.95	.92	.89	.93	.90	.88	.91	.88	.86	.85	
4	1.00	.93	.88	.84	.98	.92	.88	.84	.90	.86	.83	.88	.85	.82	.86	.83	.81	.80	
5	.95	.88	.83	.79	.94	.87	.82	.78	.85	.81	.78	.84	.80	.77	.82	.79	.76	.75	
6	.91	.83	.78	.74	.90	.83	.78	.74	.81	.77	.74	.80	.76	.73	.79	.75	.73	.71	
7	.87	.79	.74	.70	.86	.78	.73	.70	.77	.73	.69	.76	.72	.69	.75	.71	.69	.67	
8	.83	.75	.69	.65	.82	.74	.69	.65	.73	.68	.65	.72	.68	.65	.71	.67	.64	.63	
9	.79	.70	.65	.61	.78	.70	.64	.61	.69	.64	.61	.68	.63	.60	.67	.63	.60	.59	
10	.75	.66	.60	.57	.74	.65	.60	.57	.65	.60	.57	.64	.59	.56	.63	.59	.56	.55	

TESTED IN ACCORDANCE WITH CURRENT IES PROCEDURES

BALLABS CERTIFIED TEST REPORT NO.: 20331.0 DATE 04/13/18  
PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO  
DESCRIPTION: GEN7 V18 LED 4" TALL HEATSINK 4" SQ CAST HOUSING DOWNLIGHT  
ACRYLIC NARROW TIR & 4" SEMI-SPEC TRIM w/FROST FILM  
ADVANCE #XI036C100V054DSM5 @ 915mA  
CATALOG NBR: 4DS-L30/835-DIM-UNV-O-N-OF-CS  
LAMP TYPE : BXRE-35E4000

\*\*\*\*\*

ELECTRICAL CHARACTERISTICS 120.00V .2971A 35.4590W

LUMINOUS EFFICACY (LUMENS / WATTS) = 84.7

TESTED IN ACCORDANCE WITH CURRENT IES STANDARDS  
UTILIZING ABSOLUTE PHOTOMETRY PER LM-79-08

