


BALLABS CERTIFIED TEST REPORT NO.: 20318.0 DATE 04/20/18
PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
DESCRIPTION: GEN7 V13 LED 4"SHORT HEATSINK 4"SQ CAST HOUSING DOWNLIGHT
ACRYLIC MED TIR OPTIC & 4"CAST WHITE FLUSH w/SOLITE LENS
ADVANCE # XI025C070V054DSM1 @ 625mA
CATALOG NBR: 4DS-L20/835-DIM-UNV-L-M-OF-WH
LAMP TYPE : BXRE-35E2000

CANDLEPOWER DISTRIBUTION						
VERT	HORIZONTAL ANGLE					ZONAL
ANG	0	22.5	45	67.5	90	LUMENS
0	6047.	6047.	6047.	6047.	6047.	
5	5827.	5806.	5790.	5760.	5763.	552.5
10	5002.	4998.	4960.	4915.	4870.	
15	3492.	3588.	3513.	3470.	3428.	994.3
20	1942.	1973.	2008.	1920.	1829.	
25	948.	983.	987.	915.	856.	438.1
30	447.	464.	469.	421.	399.	
35	214.	231.	246.	222.	190.	141.5
40	117.	125.	133.	119.	106.	
45	77.	79.	84.	77.	72.	60.7
50	55.	56.	57.	55.	52.	
55	40.	42.	42.	41.	40.	37.0
60	33.	33.	32.	31.	31.	
65	25.	25.	24.	24.	25.	23.9
70	16.	16.	16.	16.	15.	
75	10.	10.	10.	10.	9.	10.7
80	6.	6.	5.	6.	5.	
85	2.	3.	1.	2.	2.	2.2
90	0.	0.	0.	1.	0.	



[Handwritten signature]

NVLAP[®]
TESTING

NVLAP LAB CODE 200921-0

LUMEN SUMMARY							
ZONE	LUMENS	%LAMP	%FIXT	ZONE	LUMENS	%LAMP	%FIXT
0- 30	1985.	NA.	87.8	90-120	0.	NA.	.0
0- 40	2126.	NA.	94.1	90-130	0.	NA.	.0
0- 60	2224.	NA.	98.4	90-150	0.	NA.	.0
0- 90	2261.	NA.	100.0	90-180	0.	NA.	.0

TOTAL LUMINAIRE = 0-180 2261. NA. 100.0

IES SPACING CRITERIA: END= .6 DIAGONAL = .6 CROSS= .5

THIS BALLABS REPORT WITH THE USE OF THE NVLAP LOGO SHALL NOT BE USED BY THIS CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY NVLAP, NIST, OR ANY AGENCY OF THE FEDERAL GOVERNMENT.

BALLABS CERTIFIED TEST REPORT NO.: 20318.0 DATE 04/20/18
 PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
 DESCRIPTION: GEN7 V13 LED 4"SHORT HEATSINK 4"SQ CAST HOUSING DOWNLIGHT
 ACRYLIC MED TIR OPTIC & 4"CAST WHITE FLUSH w/SOLITE LENS
 ADVANCE # XI025C070V054DSM1 @ 625mA
 CATALOG NBR: 4DS-L20/835-DIM-UNV-L-M-OF-WH
 LAMP TYPE : BXRE-35E2000

LUMINANCES-CD/SQ-M			
HORIZONTAL ANGLE			
VERT	0	45	90
ANGLE			
45	10436.	11410.	9741.
55	6690.	7033.	6690.
65	5588.	5355.	5588.
75	3802.	3802.	3422.
85	2258.	1129.	2258.

MAXIMUM BRIGHTNESSES NOT MEASURED

ZONAL CAVITY COEFFICIENTS OF UTILIZATION

EFFECTIVE FLOOR CAVITY REFLECTANCE=.20

CEILING	.80	.70	.50	.30	.10	.00													
WALL	.70	.50	.30	.10	.70	.50	.30	.10	.50	.30	.10	.50	.30	.10	.50	.30	.10	.00	
RCR																			
0	1.19	1.19	1.19	1.19	1.16	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00	
1	1.15	1.13	1.11	1.09	1.12	1.11	1.09	1.07	1.07	1.05	1.04	1.03	1.02	1.01	1.00	.99	.98	.96	
2	1.10	1.06	1.03	1.00	1.08	1.04	1.01	.99	1.01	.99	.97	.98	.96	.95	.96	.94	.93	.91	
3	1.06	1.01	.97	.94	1.04	1.00	.96	.93	.97	.94	.91	.95	.92	.90	.93	.91	.89	.87	
4	1.02	.96	.91	.88	1.00	.95	.91	.88	.93	.89	.87	.91	.88	.86	.89	.87	.85	.83	
5	.98	.91	.87	.83	.97	.90	.86	.83	.89	.85	.82	.87	.84	.81	.86	.83	.81	.79	
6	.95	.88	.83	.80	.94	.87	.83	.79	.86	.82	.79	.84	.81	.78	.83	.80	.78	.77	
7	.92	.84	.80	.76	.91	.84	.79	.76	.83	.79	.76	.81	.78	.75	.80	.77	.75	.74	
8	.88	.81	.76	.73	.87	.80	.76	.73	.79	.75	.72	.78	.75	.72	.78	.74	.72	.71	
9	.85	.77	.73	.70	.84	.77	.72	.69	.76	.72	.69	.75	.72	.69	.74	.71	.69	.68	
10	.82	.74	.69	.66	.81	.74	.69	.66	.73	.69	.66	.72	.68	.66	.71	.68	.66	.64	

TESTED IN ACCORDANCE WITH CURRENT IES PROCEDURES

BALLABS CERTIFIED TEST REPORT NO.: 20318.0 DATE 04/20/18
PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
DESCRIPTION: GEN7 V13 LED 4"SHORT HEATSINK 4"SQ CAST HOUSING DOWNLIGHT
ACRYLIC MED TIR OPTIC & 4"CAST WHITE FLUSH w/SOLITE LENS
ADVANCE # XI025C070V054DSM1 @ 625mA
CATALOG NBR: 4DS-L20/835-DIM-UNV-L-M-OF-WH
LAMP TYPE : BXRE-35E2000

ELECTRICAL CHARACTERISTICS 119.97V .2100A 24.9870W

LUMINOUS EFFICACY (LUMENS / WATTS) = 90.5

TESTED IN ACCORDANCE WITH CURRENT IES STANDARDS
UTILIZING ABSOLUTE PHOTOMETRY PER LM-79-08

