BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC.
1618 HEADLAND DR.
FENTON, MO 63026
(636) 343-6006
(636) 343-6051 FAX

SIGNIFICANCE OF THE TEST IS LIMITED TO THE DEGREE THAT THE TESTED SAMPLE IS REPRESENTATIVE. OTHER FACTORS AFFECT FIELD PERFORMANCE.

BALLABS REPORT NO. : 20798.0 I DATE: 05/06/19
PREPARED FOR: H.E.WILLIAMS, INC - CARTAHGE, MO
DESCRIPTION: 4-192 LED 22"ARRAYS EACH ON ALUM HEATSINK 24x19"HIGHBAY LUMINAIRE w/CLEAR ACRYLIC LENSES OVER LEDS & CENTER DRIVER HOUSING 2 ADVANCE #XI095C275V054BSF1 @ 1300mA
CATALOG NO.: GP4-L300/840-W-CL-DIM-UNV
LED : MADE #10560431

ELECTRICAL MEASUREMENTS

ELECTRICAL CHARACTERISTICS - INPUT TO DRIVER

	VOLT	AMPS	WATTS
Line	276.97	.7740	202.12
	PF	THDv	THDi
	0.9427	.4303	13.437

The fixture was mounted and energized within a 25 degree C environment. The electrical measurements were taken once the sample luminaire reached thermal equilibrium.