


BALLABS CERTIFIED TEST REPORT NO.: 20133.0 DATE 12/01/17
PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
DESCRIPTION: 2-56 LED 22"ARRAYS 4'RECESSED PERIMETER CONTINUOUS PX
WHITE REFLECTOR w/FROSTED ACRYLIC LENS
ADVANCE #XI054C150V054BST1 @ 800mA
CATALOG NBR: PXF-64-03'08-L10/835-W-D-LCAP/RCAP-DIM-UNV
LAMP TYPE : HLM2256_5630 REV A #10560227

0 DEGREE PLANE CONTAINS MAXIMUM CANDLEPOWER



[Handwritten signature]

NVLAP[®]
TESTING

NVLAP LAB CODE 200921-0

LUMEN SUMMARY							
ZONE	LUMENS	%LAMP	%FIXT	ZONE	LUMENS	%LAMP	%FIXT
0- 30	1574.	NA.	42.7	90-120	0.	NA.	.0
0- 40	2343.	NA.	63.5	90-130	0.	NA.	.0
0- 60	3307.	NA.	89.6	90-150	0.	NA.	.0
0- 90	3689.	NA.	100.0	90-180	0.	NA.	.0
TOTAL LUMINAIRE =				0-180	3689.	NA.	100.0

THIS BALLABS REPORT WITH THE USE OF THE NVLAP LOGO SHALL NOT BE USED BY THIS CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY NVLAP, NIST, OR ANY AGENCY OF THE FEDERAL GOVERNMENT.

BALLABS CERTIFIED TEST REPORT NO.: 20133.0 DATE 12/01/17
 PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
 DESCRIPTION: 2-56 LED 22"ARRAYS 4'RECESSED PERIMETER CONTINUOUS PX
 WHITE REFLECTOR w/FROSTED ACRYLIC LENS
 ADVANCE #XI054C150V054BST1 @ 800mA
 CATALOG NBR: PXF-64-03'08-L10/835-W-D-LCAP/RCAP-DIM-UNV
 LAMP TYPE : HLM2256_5630 REV A #10560227

CANDLEPOWER DISTRIBUTION
 0 DEGREE PLANE CONTAINS MAXIMUM CANDLEPOWER

VERT	HORIZONTAL									LUMENS		TOTAL
	.0	22.5	45.0	67.5	90.0	112.5	135.0	157.5	180.0	FRONT	BACK	
0	2274.	2274.	2274.	2274.	2274.	2274.	2274.	2274.	2274.			
5	2304.	2340.	2330.	2301.	2277.	2296.	2265.	2233.	2233.	110.8	108.1	218.9
10	2324.	2348.	2342.	2312.	2257.	2256.	2205.	2090.	2107.			
15	2276.	2301.	2305.	2284.	2216.	2180.	2022.	1695.	1657.	325.0	274.6	599.6
20	2140.	2163.	2206.	2218.	2139.	2058.	1582.	953.	800.			
25	1948.	1984.	2082.	2118.	2042.	1879.	985.	545.	482.	474.6	280.5	755.1
30	1723.	1769.	1928.	1990.	1917.	1657.	585.	354.	310.			
35	1507.	1568.	1720.	1827.	1744.	1295.	387.	211.	207.	533.1	236.5	769.6
40	1170.	1320.	1478.	1635.	1531.	907.	229.	200.	205.			
45	694.	818.	1264.	1418.	1317.	575.	184.	200.	205.	432.8	150.0	582.9
50	451.	476.	968.	1201.	1092.	345.	180.	200.	205.			
55	316.	308.	557.	999.	857.	194.	176.	198.	201.	293.1	88.0	381.1
60	261.	258.	324.	790.	652.	134.	168.	190.	180.			
65	190.	196.	234.	587.	482.	124.	157.	163.	151.	194.1	71.3	265.4
70	130.	131.	163.	294.	316.	110.	131.	125.	118.			
75	89.	83.	103.	126.	184.	94.	94.	81.	81.	55.5	46.4	101.9
80	55.	44.	57.	58.	82.	57.	56.	44.	48.			
85	25.	14.	20.	14.	18.	17.	21.	10.	14.	7.8	7.2	15.0
90	2.	1.	1.	4.	4.	2.	4.	0.	0.			

USE .500 FT. AS LENGTH AND 3.708 FT. AS WIDTH

BALLABS CERTIFIED TEST REPORT NO.: 20133.0 DATE 12/01/17
 PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
 DESCRIPTION: 2-56 LED 22"ARRAYS 4'RECESSED PERIMETER CONTINUOUS PX
 WHITE REFLECTOR w/FROSTED ACRYLIC LENS
 ADVANCE #XI054C150V054BST1 @ 800mA
 CATALOG NBR: PXF-64-03'08-L10/835-W-D-LCAP/RCAP-DIM-UNV
 LAMP TYPE : HLM2256_5630 REV A #10560227

ZONAL CAVITY COEFFICIENTS OF UTILIZATION

EFFECTIVE FLOOR CAVITY REFLECTANCE=.20

CEILING	.80				.70				.50				.30				.10				.00
WALL	.70	.50	.30	.10	.70	.50	.30	.10	.50	.30	.10	.50	.30	.10	.50	.30	.10	.50	.30	.10	.00
RCR																					
0	1.19	1.19	1.19	1.19	1.16	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00			
1	1.12	1.08	1.05	1.02	1.09	1.06	1.03	1.00	1.02	1.00	.97	.98	.96	.94	.95	.93	.92	.90			
2	1.04	.98	.93	.88	1.02	.96	.91	.87	.93	.89	.85	.90	.86	.84	.87	.84	.82	.80			
3	.97	.89	.83	.77	.95	.88	.82	.77	.85	.80	.76	.82	.78	.74	.80	.76	.73	.71			
4	.90	.81	.74	.68	.88	.80	.73	.68	.77	.72	.67	.75	.70	.66	.73	.69	.65	.64			
5	.84	.73	.66	.60	.82	.72	.65	.60	.70	.64	.59	.68	.63	.59	.67	.62	.58	.56			
6	.78	.67	.60	.54	.77	.66	.59	.54	.64	.58	.53	.63	.57	.53	.61	.56	.53	.51			
7	.73	.61	.54	.49	.71	.61	.53	.48	.59	.53	.48	.58	.52	.48	.57	.51	.47	.46			
8	.68	.56	.48	.43	.66	.55	.48	.43	.54	.48	.43	.53	.47	.43	.52	.46	.42	.41			
9	.63	.51	.44	.39	.62	.50	.43	.38	.49	.43	.38	.48	.42	.38	.47	.42	.38	.36			
10	.59	.47	.40	.35	.58	.46	.39	.35	.45	.39	.35	.44	.38	.34	.43	.38	.34	.33			

TESTED IN ACCORDANCE WITH CURRENT IES PROCEDURES

BALLABS CERTIFIED TEST REPORT NO.: 20133.0 DATE 12/01/17
PREPARED FOR: H.E. WILLIAMS, INC - CARTHAGE, MO
DESCRIPTION: 2-56 LED 22"ARRAYS 4'RECESSED PERIMETER CONTINUOUS PX
WHITE REFLECTOR w/FROSTED ACRYLIC LENS
ADVANCE #XI054C150V054BST1 @ 800mA
CATALOG NBR: PXF-64-03'08-L10/835-W-D-LCAP/RCAP-DIM-UNV
LAMP TYPE : HLM2256_5630 REV A #10560227

ELECTRICAL CHARACTERISTICS 120.03V .3107A 30.0860W

LUMINOUS EFFICACY (LUMENS / WATTS) = 99.5

TESTED IN ACCORDANCE WITH CURRENT IES STANDARDS
UTILIZING ABSOLUTE PHOTOMETRY PER LM-79-08

